

TEST REPORT

TO: Ridgeline Montessori Pub Charter/Atten: Seth Sadofsky
4500 W Amazon Drive
Eugene, OR 97401

03/01/2018

RIDMONT

PO#:

Collection Information

Date: 02/10/2018
Time: 1025
By: NA
Lab #: 20180213-016
Location: staff 1st

Lab Receipt Information

02/13/2018
1054
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0157		0.001	mg/l	0.020	02/28/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Ridgeline Montessori Pub Charter/Atten: Seth Sadofsky
4500 W Amazon Drive
Eugene, OR 97401

03/01/2018

RIDMONT

PO#:

Collection Information

Date: 02/10/2018
Time: 1030
By: NA
Lab #: 20180213-017
Location: staff 2nd

Lab Receipt Information

02/13/2018
1054
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0017		0.001	mg/l	0.020	02/14/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

Customer

TEST REPORT

TO: Ridgeline Montessori Pub Charter/Atten: Seth Sadofsky
4500 W Amazon Drive
Eugene, OR 97401

03/01/2018

RIDMONT

PO#:

Collection Information

Date: 02/10/2018
Time: 1035
By: NA
Lab #: 20180213-018
Location: Staff 2nd B

Lab Receipt Information

02/13/2018
1054
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0039		0.001	mg/l	0.020	02/14/2018	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

